





<b>Prüfbericht - Nr.:</b> <i>Test Report No.:</i>	50225111 001	<b>Auftrags-Nr.:</b> <i>Order No.:</i>	164145334	<b>Seite 1 von 26</b> <i>Page 1 of 26</i>
<b>Kunden-Referenz-Nr.:</b> <i>Client Reference No.:</i>	632179	<b>Auftragsdatum:</b> <i>Order date:</i>	Oct. 22, 2018	
<b>Auftraggeber:</b> <i>Client:</i>	EAST Group Co., Ltd.			
<b>Prüfgegenstand:</b> <i>Test item:</i>	Grid-tied PV Inverter			
<b>Bezeichnung / Typ-Nr.:</b> <i>Identification / Type No.:</i>	EA2KSI, EA2.5KSI, EA3KSI, EA3KSI-D,EA3.68KSI, EA4KSI, EA4.6KSI, EA5KSI, EA6KSI			
<b>Auftrags-Inhalt:</b> <i>Order content:</i>	AK Certification			
<b>Prüfgrundlage:</b> <i>Test specification:</i>	UTE C 15-712-1: 2013 DIN VDE 0126-1-1(VDE V 0126-1-1): 2013-08/ VFR 2014 Enedis-NOI-RES_13E: 2016			
<b>Wareneingangsdatum:</b> <i>Date of receipt:</i>	Oct. 22, 2018			
<b>Prüfmuster-Nr.:</b> <i>Test sample No.:</i>	1#			
<b>Prüfzeitraum:</b> <i>Testing period:</i>	Oct. 22, 2018 – Feb. 11, 2019			
<b>Ort der Prüfung:</b> <i>Place of testing:</i>	See page 4			
<b>Prüflaboratorium:</b> <i>Testing Laboratory:</i>	TÜV Rheinland (Shenzhen) Co., Ltd.			
<b>Prüfergebnis*:</b> <i>Test Result*:</i>	<b>Pass</b>			
<b>geprüft/ tested by:</b>		<b>kontrolliert/ reviewed by:</b>		
 Feb. 18, 2019 <b>Corney Zhang / PE</b> Datum Name/Stellung Unterschrift Date Name/Position Signature		 Feb. 18, 2019 <b>Dean Cao/ Reviwer</b> Datum Name/Stellung Unterschrift Date Name/Position Signature		
<b>Sonstiges/ Other Aspects:</b>				
– See the following pages for General product information and comment.				
<b>Zustand des Prüfgegenstandes bei Anlieferung:</b> <i>Condition of test item at delivery:</i>		Prüfmuster vollständig und unbeschädigt <i>Test item complete and undamaged</i>		
* Legende: 1 = sehr gut 2 = gut 3 = befriedigend 4 = ausreichend 5 = mangelhaft P(ass) = entspricht o.g. Prüfgrundlage(n) F(ail) = entspricht nicht o.g. Prüfgrundlage(n) N/A = nicht anwendbar N/T = nicht getestet Legend: 1 = very good 2 = good 3 = satisfactory 4 = sufficient 5 = poor P(ass) = passed a.m. test specification(s) F(ail) = failed a.m. test specification(s) N/A = not applicable N/T = not tested				
<b>Dieser Prüfbericht bezieht sich nur auf das o.g. Prüfmuster und darf ohne Genehmigung der Prüfstelle nicht auszugsweise vervielfältigt werden. Dieser Bericht berechtigt nicht zur Verwendung eines Prüfzeichens.</b> This test report only relates to the a. m. test sample. Without permission of the test center this test report is not permitted to be duplicated in extracts. This test report does not entitle to carry any test mark. V04				

<b>TEST REPORT</b> <b>UTE C 15-712-1</b> <b>LOW-VOLTAGE ELECTRICAL INSTALLATIONS</b> <b>PRACTICAL GUIDE</b> <b>Photovoltaic installations connected to the public distribution network</b>	
Report Reference No. ....:	50225111 001
Tested by (name + signature) .....	See cover page .....
Approved by (name + signature) ..:	See cover page .....
Date of issue.....:	See cover page
Testing Laboratory .....	TÜV Rheinland (Shenzhen) Co., Ltd.
Address .....	1F East & 2-4F, Cybio Technology Building No.1, No.16 Kejibei 2nd Road, High-Tech Industrial Park North Nanshan District, 518057, Shenzhen, China
Testing location/ procedure.....:	CBTL <input type="checkbox"/> TMP <input type="checkbox"/> WMT <input checked="" type="checkbox"/> SMT <input type="checkbox"/> RMT <input type="checkbox"/> CCATL <input type="checkbox"/>
Testing location/ address .....	See over page
Applicant's name .....	EAST Group Co., Ltd.
Address .....	No.6 Northern Industry Road, Songshan Lake Sci.& Tech. industrial zone, Dongguan City, Guangdong province, China
Test specification:	
Standard .....	UTE C 15-712-1: 2013 DIN VDE 0126-1-1(VDE V 0126-1-1): 2013-08
Reference standard.....:	Enedis-NOI-RES_13E: 2016
Test procedure .....	AK certificate
Non-standard test method.....:	N/A
Test Report Form No.....:	MS-0024998-appendix 34 V.0
Test Report Form(s) Originator ...:	TÜV Rheinland Group
Master TRF.....:	2013-03
Test item description .....	Photovoltaic grid-connected inverter
Trade Mark .....	
Manufacturer .....	As applicant
Model/Type reference .....	See rating label and model list for detail
Ratings .....	See rating label and model list for detail

**Testing procedure and testing location:**

<input type="checkbox"/>	<b>CB Testing Laboratory:</b>	See cover page
	Testing location/ address .....	See cover page
<input type="checkbox"/>	<b>Associated CB Test Laboratory:</b>	
	Testing location/ address .....	
	Tested by (name + signature) .....	See cover page .....
	Approved by (+ signature) .....	See cover page .....
<input type="checkbox"/>	Testing procedure: TMP	
	Tested by (name + signature) .....	
	Approved by (+ signature) .....	
	Testing location/ address .....	
<input type="checkbox"/>	Testing procedure: WMT	
	Tested by (name + signature) .....	
	Witnessed by (+ signature) .....	
	Approved by (+ signature) .....	
	Testing location/ address .....	
<input type="checkbox"/>	Testing procedure: SMT	
	Tested by (name + signature) .....	
	Approved by (+ signature) .....	
	Supervised by (+ signature) .....	
	Testing location/ address .....	
<input type="checkbox"/>	Testing procedure: RMT	
	Tested by (name + signature) .....	
	Approved by (+ signature) .....	
	Supervised by (+ signature) .....	
	Testing location/ address .....	

**List of Attachments (including a total number of pages in each attachment):**

ATTACHMENT 1 – Test report for DIN VDE 0126-1-1: 2013 (27 pages)

ATTACHMENT 2 – Photo documents (8 pages)

**Summary of testing**
**Tests performed (name of test and test clause):**


9. Frequency monitoring test

Remark: N/A


**Testing location:**
**CCIC Southern Electronic Product Testing(Shenzhen) Co., Ltd.**


Electronic Testing Building, Shahe Road 43 Xili,  
Nanshan District, Shenzhen, China


**Copy of marking plate:**




PV Inverter	
Model	EA2KSI
Max.Input Voltage	600Vd.c.
MPPT Voltage Range	90~550Vd.c.
Max.Input Current	11A
Isc PV	12A
Rated Output Voltage	230Va.c.
Rated Output Frequency	50/60Hz
Max.Output Current	8.7A
Rated Output Power	2000W
Power Factor Range	0.8 cap~0.8 ind.
Enclosure	IP65
Overvoltage Category	III(AC), II (DC)
Ambient Temperature	-25°C~60°C



Protection Class I  
EA2KSI201808150001





PV Inverter	
Model	EA2.5KSI
Max.Input Voltage	600Vd.c.
MPPT Voltage Range	90~550Vd.c.
Max.Input Current	11A
Isc PV	12A
Rated Output Voltage	230Va.c.
Rated Output Frequency	50/60Hz
Max.Output Current	10.9A
Rated Output Power	2500W
Power Factor Range	0.8 cap~0.8 ind.
Enclosure	IP65
Overvoltage Category	III(AC), II (DC)
Ambient Temperature	-25°C~60°C


Protection Class I  
EA2.5KSI201808150001



**EAST**
**PV Inverter**

Model	EA3KSI
Max.Input Voltage	600Vd.c.
MPPT Voltage Range	90~550Vd.c.
Max.Input Current	11A
Isc PV	12A
Rated Output Voltage	230Va.c.
Rated Output Frequency	50/60Hz
Max.Output Current	13.0A
Rated Output Power	3000W
Power Factor Range	0.8 cap~0.8 ind.
Enclosure	IP65
Overvoltage Category	III(AC), II (DC)
Ambient Temperature	-25°C~60°C



Protection Class I


**EAST**
**PV Inverter**

Model	EA3KSI-D
Max.Input Voltage	600Vd.c.
MPPT Voltage Range	90~550Vd.c.
Max.Input Current	11A*2
Isc PV	12A*2
Rated Output Voltage	230Va.c.
Rated Output Frequency	50/60Hz
Max.Output Current	13.0A
Rated Output Power	3000W
Power Factor Range	0.8 cap~0.8 ind.
Enclosure	IP65
Overvoltage Category	III(AC), II (DC)
Ambient Temperature	-25°C~60°C



Protection Class I


**EAST**
**PV Inverter**

Model	EA3.68KSI
Max.Input Voltage	600Vd.c.
MPPT Voltage Range	90~550Vd.c.
Max.Input Current	11A*2
Isc PV	12A*2
Rated Output Voltage	230Va.c.
Rated Output Frequency	50/60Hz
Max.Output Current	16.0A
Rated Output Power	3680W
Power Factor Range	0.8 cap~0.8 ind.
Enclosure	IP65
Overvoltage Category	III(AC), II (DC)
Ambient Temperature	-25°C~60°C



Protection Class I


**EAST**
**PV Inverter**

Model	EA4KSI
Max.Input Voltage	600Vd.c.
MPPT Voltage Range	90~550Vd.c.
Max.Input Current	11A*2
Isc PV	12A*2
Rated Output Voltage	230Va.c.
Rated Output Frequency	50/60Hz
Max.Output Current	17.4A
Rated Output Power	4000W
Power Factor Range	0.8 cap~0.8 ind.
Enclosure	IP65
Overvoltage Category	III(AC), II (DC)
Ambient Temperature	-25°C~60°C



Protection Class I



**EAST**
**PV Inverter**

Model	EA4.6KSI
Max.Input Voltage	600Vd.c.
MPPT Voltage Range	90~550Vd.c.
Max.Input Current	11A*2
Isc PV	12A*2
Rated Output Voltage	230Va.c.
Rated Output Frequency	50/60Hz
Max.Output Current	20.0A
Rated Output Power	4600W
Power Factor Range	0.8 cap~0.8 ind.
Enclosure	IP65
Overvoltage Category	III(AC), II (DC)
Ambient Temperature	-25°C ~60°C



Protection Class I

EA4.6KSI201808150001


**EAST**
**PV Inverter**

Model	EA5KSI
Max.Input Voltage	600Vd.c.
MPPT Voltage Range	90~550Vd.c.
Max.Input Current	11A*2
Isc PV	12A*2
Rated Output Voltage	230Va.c.
Rated Output Frequency	50/60Hz
Max.Output Current	21.8A
Rated Output Power	5000W
Power Factor Range	0.8 cap~0.8 ind.
Enclosure	IP65
Overvoltage Category	III(AC), II (DC)
Ambient Temperature	-25°C ~60°C



Protection Class I

EA5KSI201808150001


**EAST**
**PV Inverter**

Model	EA6KSI
Max.Input Voltage	600Vd.c.
MPPT Voltage Range	90~550Vd.c.
Max.Input Current	11A*2
Isc PV	12A*2
Rated Output Voltage	230Va.c.
Rated Output Frequency	50/60Hz
Max.Output Current	26.1A
Rated Output Power	6000W
Power Factor Range	0.8 cap~0.8 ind.
Enclosure	IP65
Overvoltage Category	III(AC), II (DC)
Ambient Temperature	-25°C ~60°C



Protection Class I

EA6KSI201808150001



Equipment mobility.....	: <input type="checkbox"/> movable <input type="checkbox"/> hand-held <input type="checkbox"/> stationary <input checked="" type="checkbox"/> fixed <input type="checkbox"/> transportable <input type="checkbox"/> for building-in
Connection to the mains .....	: <input type="checkbox"/> pluggable equipment <input type="checkbox"/> direct plug-in <input checked="" type="checkbox"/> permanent connection <input type="checkbox"/> for building-in
Environmental category .....	: <input checked="" type="checkbox"/> outdoor <input type="checkbox"/> indoor <input type="checkbox"/> indoor conditional
Operating condition.....	: <input checked="" type="checkbox"/> continuous <input type="checkbox"/> short-time <input type="checkbox"/> intermittent
Over voltage category mains .....	: <input type="checkbox"/> OVC I <input type="checkbox"/> OVC II <input checked="" type="checkbox"/> OVC III <input type="checkbox"/> OVC IV
Over voltage category PV .....	: <input type="checkbox"/> OVC I <input checked="" type="checkbox"/> OVC II <input type="checkbox"/> OVC III <input type="checkbox"/> OVC IV
Mains supply tolerance (%).....	: According to specified supply range
Tested for IT power systems .....	: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
IT testing, phase-phase voltage (V) .....	: N/A
Class of equipment .....	: <input checked="" type="checkbox"/> Class I <input type="checkbox"/> Class II <input type="checkbox"/> Class III <input type="checkbox"/> Not classified
Mass of equipment (kg).....	: See model list
Pollution degree .....	: <input type="checkbox"/> PD 1 <input checked="" type="checkbox"/> PD 2 (inside) <input checked="" type="checkbox"/> PD 3 (outside)
IP protection class .....	: IP65

**Possible test case verdicts:**

- test case does not apply to the test object..... : N/A
- test object was not evaluated for the requirement..... : N/E
- test object does meet the requirement .....
- test object does not meet the requirement .....

**Testing:**

- Date of receipt of test items..... : See cover page
- Date(s) of performance of tests..... : See cover page

**General remarks:**

"(see Attachment #)" refers to additional information appended to the report.

"(see appended table)" refers to a table appended to the report.

The tests results presented in this report relate only to the object tested.

This report shall not be reproduced except in full without the written approval of the testing laboratory.

List of test equipment must be kept on file and available for review.

Additional test data and/or information provided in the attachments to this report.

Throughout this report a  comma /  point is used as the decimal separator.

**Manufacturer's Declaration per sub-clause 6.2.5 of IEC 60335-1:**

- The application for obtaining a CB Test Certificate includes more than one factory location and a declaration from the Manufacturer stating that the sample(s) submitted for evaluation is (are) representative of the products from each factory has been provided :**
- Yes  
 Not applicable

**When differences exist; they shall be identified in the General product information section.**

**Name and address of factory (ies)**

**: EAST Group Co., Ltd.**

NO.6 NORTHERN INDUSTRY No.6 Northern Industry  
Road, Songshan Lake Sci.& Tech. industrial zone,  
Dongguan City, Guangdong province, China



**General product information:**
Brief description:

The equipment is single phase utility-interactive type PV inverter which will be installed and connected to the grid network after installation.

It contains filters for smoothing the output voltage and for EMC, switching and control circuits. Electronic circuits are mounted on a number of PCBs interconnected by appropriate connectors and wires. Power board including electronics components is mounted on the heat sink to earthing by metal screw and spring washer.

There are included a RS485 and two RJ45 communication ports which are connected to the monitors to monitor the status of the inverter by proprietary software.

The PV input combine with 1 or 2 string MPPT tracer and PV input terminals. AC output direct connected to grid and Protective Earthing are provided by dedicated earthing terminals. Grid is protected combination with a two series of relays as redundant build for ensure the inverter can independent disconnected from grid while a relay was fault.

During fault condition defined in this standard, after the DSP receives the abnormal signal from the relevant protective detection circuit, the relays will operate to disconnect the PV inverter line and neutral from grid automatically.

The master DSP and slaver DSP has capacity independent disconnected from grid, when any grid fault had happened.

operation conditions.


Block Diagram:


Figure 1. Block diagram

Model Difference:

The models EA2KSI, EA2.5KSI, EA3KSI are identical to hardware and software, excepted the output power are different was adjusted by software.

The Models EA3KSI-D, EA3.68KSI, EA4KSI, EA4.6KSI, EA5KSI, EA6KSI are identical to hardware and software, excepted the output power are different was adjusted by software and internal cooling fan within EA6KSI.

The models EA2KSI, EA2.5KSI, EA3KSI and models EA3KSI-D, EA3.68KSI, EA4KSI, EA4.6KSI, EA5KSI, EA6KSI are same as software and hardware, excepted 9 below components are different:

Model Components	EA2KSI, EA2.5KSI, EA3KSI	EA3KSI-D, EA3.68KSI, EA4KSI EA4.6KSI, EA5KSI, EA6KSI
Max. input current	11A	11A×2
Output current sensor	HLSR 20-P/LEM	HLSR 32-P/LEM
MPPT string	1	2
Boost induct	580uH(11A)*1	580uH(11A)*2
BUS capacitor	1200uF(315V)*4	1200uF(315V)*6
IGBT/MOSFET	IKW40N65H5*5, IKW40N120H3*2	IKW40N65H5*6, IKW40N120H3*2
Power board size	262mm*216mm	322mm*231.5mm
Overall size (WxDxH) [mm]	308x116.5x353	370x126.5x420

**Model list:**

MODEL LIST 1		EA2KSI	EA2.5KSI	EA3KSI	EA3KSI-D
<b>INPUT(PV)</b>	V <sub>MAX</sub> PV [Vdc]	600			
	I <sub>SC</sub> PV [A]	12			2x12
	MPP Voltage Range V <sub>MPP</sub> [Vdc]	90-550			
	Max. PV Input Current [A]	11			11x2
	MPP Full Power Voltage Range [Vdc]	200-480	250-480	300-480	150-480
	Input PV Operating Voltage Range [Vdc]	90-600			
	Start PV Voltage [Vdc]	120			
	Backfeed Current [A]	0			
	Overvoltage Category (OVC)	OVC II			
<b>GRID CONNECTION</b>	Rated Output Voltage Ur [Vac]	230			
	Normal Operating Voltage Range Un [Vac]	180-280			
	Rated Output Frequency F <sub>NETZ</sub> [Hz]	50/60			
	Normal Operating Frequency Range Fn [Hz]	45 - 55 / 55 - 65			
	Rated Output Power P <sub>E</sub> [W]	2000	2500	3000	3000
	Max. Output Current I <sub>max</sub> [A]	8.7	10.9	13	13
	Power Factor cosφ [λ]	0.8 cap-0.8ind adjustable (default: 1)			
	Efficiency max. η <sub>max</sub> [%]	97.8			
	Night Power Consumption [W]	< 0.5			
	THD [V / I] (100% full power)	< 3%			
Acoustic Noise [dB]	< 40				

	Overvoltage Category (OVC)	OVC III	
<b>SYSTEM</b>	Type of inverter	Non-transformer	
	Firmware [DSP/MCU]	MDSP: V009, MCU: V009	
	Separated by	Transformerless	
	MPPT strings	1	2
	MPPT tracking	1	2
	Protective Class	1	
	Enclosure Protection (IP)	IP65	
	Operating Temperature Range [°C]	-25-60	
	Pollution degree (PD)	PD3 for outside, PD2 for inside	
	Altitude [m]	4000 (> 2000 derating power)	
	Weight [kg]	< 9	< 11.5
	Size (WxDxH) [mm]	308x116.5x353	370x126.5x420
Note:			

MODEL LIST 2		EA3.68KSI	EA4KSI	EA4.6KSI	EA5KSI	EA6KSI
<b>INPUT(PV)</b>	V <sub>MAX</sub> PV [Vdc]	600				
	I <sub>SC</sub> PV [A]	2x12				
	MPP Voltage Range V <sub>MPP</sub> [Vdc]	90-550				
	Max. PV Input Current [A]	11x2				
	MPP Full Power Voltage Range [Vdc]	200-480		230-480	250-480	300-480
	Input PV Operating Voltage Range [Vdc]	90-600				
	Start PV Voltage [Vdc]	120				
	Backfeed Current [A]	0				
	Overvoltage Category (OVC)	OVC II				
<b>GRID CONNECTION</b>	Rated Output Voltage U <sub>r</sub> [Vac]	230				
	Normal Operating Voltage Range U <sub>n</sub> [Vac]	180-280				
	Rated Output Frequency F <sub>NETZ</sub> [Hz]	50/60				
	Normal Operating Frequency Range F <sub>n</sub> [Hz]	45 - 55 / 55 - 65				
	Rated Output Power P <sub>E</sub> [W]	3680	4000	4600	5000	6000
	Max. Output Current I <sub>max</sub> [A]	16	17.4	20	21.8	26.1
	Power Factor cosφ [λ]	0.8 cap-0.8ind adjustable (default: 1)				

	Efficiency max. $\eta_{\max}$ [%]	97.8
	Night Power Consumption [W]	< 0.5
	THD [ $V / I$ ] (100% full power)	< 3%
	Acoustic Noise [dB]	< 40
	Oversvoltage Category (OVC)	OVC III
<b>SYSTEM</b>	Type of inverter	Non-transformer
	Firmware [DSP/MCU]	MDSP: V009, MCU: V009
	Separated by	Transformerless
	MPPT strings	2
	MPPT tracking	2
	Protective Class	1
	Enclosure Protection (IP)	IP65
	Operating Temperature Range [°C]	-25-60
	Pollution degree (PD)	PD3 for outside, PD2 for inside
	Altitude [m]	4000 (> 2000 derating power)
	Weight [kg]	< 11.5
	Size (WxDxH) [mm]	370x126.5x420
Note:		

Protection function of PGU:

1. Over & under grid voltage protection.
2. Over & under grid frequency protection.
3. Anti-islanding protection.
4. NS & NA protection redundantly.
5. Relays used in series for grid auto-disconnection devices.
6. Short-circuit protection rely on external circuits break which was specified in installation manual.
7. Over temperature derating and protection.
8. Over current protection.
9. Relay function self-check.

Throughout the test report following abbreviations may be used:

- |       |                             |       |                   |
|-------|-----------------------------|-------|-------------------|
| • cl  | clearance                   | • int | internal distance |
| • dcr | creepage distance           | • o-c | open-circuit      |
| • dti | distance through insulation | • o-l | overload          |

•	PCE	Power Conversion Equipment	•	s-c	short-circuit
•	BI	basic insulation	•	SI	supplementary insulation
•	DI	double insulation	•	RI	reinforced insulation

UTE C 15-712-1			
Clause	Requirement – Test	Result - Remark	Verdict
<b>5</b>	<b>Description of PV installations</b>	Must be taken under consideration for the installation.	N/A

<b>6.</b>	<b>Earthing of the installation</b>	See below	P
<b>6.1</b>	<b>Diagrams showing bonding of alternating current part with earth</b>	See below.	P
	Diagrams showing bonding of alternating current part with earth. The earthing system has been produced in accordance with the requirements of NF C 15-100.	Compliance.	P
<b>6.2</b>	<b>Earthing of one polarity in the d.c. part</b>	See below.	N/A
	In a PV installation, the protection devices against indirect contact are independent of the principle of the earthing systems. The direct current part is created in accordance with the rules for class II or equivalent isolation.	No polarity of dc part connected to the earth.	N/A
<b>6.3</b>	<b>Earthing of conductive masses and elements</b>	See below.	P
<b>6.3.1</b>	<b>Direct current part</b>	See below.	P
	To minimise the effects of induced overvoltages, the metal structures of the modules and the metal support structures (including the metal cable runs) must be connected to equipotential bonding, which in turn is connected to the earth.	All conductive parts of inverter case have connected to earth.	P
<b>6.3.2</b>	<b>Alternating current part</b>	See below.	P
	All chassis on the a.c. side must be connected to the earth via a protective conductor that meets the requirements of paragraph 411.3.1.2 and section 5-54 of NF C 15-100. If a transformer is installed outside the inverter (low voltage/low voltage or high voltage/low voltage transformer), equipotential bonding is required between these items of equipment.	All conductive parts of inverter case have connected to earth.	P
<b>6.3.3</b>	<b>Inverter</b>	See below.	P
	The inverter body must be connected to the equipotential bonding via a conductor with a minimum cross-section of 6mm <sup>2</sup> Cu or equivalent and to the protective conductor of the a.c. part.	All conductive parts of inverter case have connected to earth.	P

<b>7.</b>	<b>Protection against electric shock</b>	See below.	P
<b>7.1</b>	<b>General points</b>	See below.	P
	The PV equipment of the direct current part must be treated as being under voltage, even if it is disconnected from the alternating current part.	Compliance.	P
<b>7.2</b>	<b>Protection against direct contact</b>	See below.	P
<b>7.2.1</b>	<b>General case</b>	See below.	P

UTE C 15-712-1			
Clause	Requirement – Test	Result - Remark	Verdict
	Electrical equipment must be fitted with a form of protection either by insulation of the live parts or through a casing	Reinforce or double insulation are provided between accessible live parts and main circuits.	P
<b>7.2.2</b>	<b>Particular case of safety extra-low voltage and protective extra-low voltage</b>	See below.	N/A
	If the nominal voltage of the safety extra-low voltage circuit is less than or equal to 25 V rms a.c. or 60 V d.c. without ripple, protection against direct contact through insulation of the live parts or a casing is not necessary.	No extra-low voltage circuit.	N/A
<b>7.3</b>	<b>Protection against indirect contact</b>	See below.	P
<b>7.3.1</b>	<b>General points</b>	See below.	P
	The regulations for protection against indirect contact are set out in section 4-41 of NF C 15-100.  The circuits covered by 411.3.3 of standard NF C 15-100 and, in particular, circuits in residential buildings must be protected with a differential device with a sensitivity of 30 mA or less.	Compliance.	P
<b>7.3.2</b>	<b>Direct current part.</b>	See below.	P
	For the direct current part (PV modules, junction boxes, chain cables, group cables, marshalling boxes or cabinets, etc.), protection against indirect contact must be ensured	Double or reinforce insulation between direct current and accessible parts have been provided.	P
<b>7.3.2.1</b>	<b>Protection with safety extra-low voltage or protective extra-low voltage</b>	See below.	N/A
	The requirements of article 414 of standard NF C 15-100 must be applied. The voltage $U_{ocMAX}$ must not exceed 120 V.	No extra-low voltage circuit.	N/A
<b>7.3.2.2</b>	<b>Protection with double or reinforced insulation</b>	See below.	P
	The requirements of article 412 of standard NF C 15-100 must be applied.	Double or reinforce insulation between direct current and accessible parts have been provided.	P
<b>7.3.3</b>	<b>Alternating current part</b>	See below.	P
	Protection against indirect contact is ensured through double or reinforced insulation or by an automatic cut-out of the supply, according to one of the following measures: <ul style="list-style-type: none"> <li>• In a TT system: cut-out on the first fault;</li> <li>• In a TN system: cut-out on the first fault;</li> <li>• In an IT system: cut-out on the second fault.</li> </ul>	The unit is only intended for TT or TN systems. The residual current protection device is provided and compliant the requirements.	P

UTE C 15-712-1			
Clause	Requirement – Test	Result - Remark	Verdict
<b>8</b>	<b>Overcurrent protection</b>	See below.	N/A
<b>8.1</b>	<b>Direct current part</b>	See below.	N/A
<b>8.1.1</b>	<b>General points</b>	See below.	N/A
	See figure 6 of this standard	Must be taken under consideration for the installation.	N/A
<b>8.1.2</b>	<b>Protection of PV modules</b>	See below.	N/A
	In an installation with several PV module chains in parallel, the modules must be protected against the effect of reverse currents that may be generated in the chains in the event of a fault.	Must be taken under consideration for the installation.	N/A
<b>8.1.3</b>	<b>Protection of PV chain cables</b>	See below.	N/A
	The sizing of the PV chain cables takes into account the choice of protection device for the PV modules adopted in 8.1.2.	Must be taken under consideration for the installation.	N/A
<b>8.1.4</b>	<b>Protection of PV group cables</b>	See below.	N/A
	In an installation with several PV groups in parallel, the cables for the groups must be protected against the effect of reverse currents caused by a short circuit in a group.	Must be taken under consideration for the installation.	N/A
<b>8.1.5</b>	<b>Protection of main PV cable</b>	See below.	N/A
	The main cable of a PV generator must be dimensioned with a permissible current $I_z$ greater than or equal to $1.25 I_{scSTC\_gen}$ .	Must be taken under consideration for the installation.	N/A
<b>8.1.6</b>	<b>Characteristics of overcurrent protection devices</b>	See below.	N/A
	The overcurrent protection devices must be either fuses compliant with standard NF EN 60269-1 or circuit-breakers compliant with standard NF EN 60947-2. These devices must be implemented for both polarities, regardless of the configuration of the installation.	The dc circuit breaker is required to be installed additionally in accordance to NF EN 60947-2.	N/A
<b>8.2</b>	<b>Alternating current part</b>	See below.	N/A
<b>8.2.1</b>	<b>General points</b>	See below.	N/A
	In the case of an installation connected to the network via a branch line with limited power, the minimum cross-section of the conductors connected to the terminals downstream of the general isolating and protection device is 10 mm <sup>2</sup> Cu.	Must be taken under consideration for the installation.	N/A
<b>8.2.2</b>	<b>Overload protection</b>	See below.	N/A
	Alternating current circuits are protected against surges in accordance with the requirements of article 433 of standard NF C 15-100.	The ac circuit breaker is required to be installed additionally.	N/A



UTE C 15-712-1			
Clause	Requirement – Test	Result - Remark	Verdict
<b>8.2.3</b>	<b>Short-circuit protection</b>	See below.	N/A
	In the case of a short circuit in an inverter or its line, the inverter is regarded as the load and the public network as the source.	The ac circuit breaker is required to be installed additionally.	N/A

<b>9.</b>	<b>Tripping device</b>	See below.	P
	<p>This protection device is designed to disconnect generators in the event of:</p> <ul style="list-style-type: none"> <li>• a fault on the public distribution network;</li> <li>• a failure in the supply from the public distribution network;</li> <li>• fluctuations in the voltage or frequency greater than those specified by the distributor.</li> </ul>	<p>The unit provides an integrated disconnection facility according to VDE 0126-1-1 and it is rated below 250kW.</p> <p>See test report No. 50225111 001 attachment 1 for detail.</p> <p>See table 9 for the deviation of over frequency limit VDE 0126-1-1: 2013.</p>	P
<b>10</b>	<b>Prevention of degradation of photovoltaic installations</b>	See below.	N/A
	In order to prevent the degradation of PV installations due to specific external influences and the presence of direct current, and despite the implementation of measures such as the installation of double insulation and monoconductor cables, additional measures must be implemented for the direct current part.	Must be taken under consideration for the installation.	N/A

<b>11</b>	<b>Voltage drop</b>	See below.	N/A
<b>11.1</b>	<b>General points</b>	See below.	N/A
	The objective of technical and commercial optimisations is to minimise voltage drops.	Must be taken under consideration for the installation.	N/A
<b>11.2</b>	<b>Direct current installation</b>	See below.	N/A
	The authorised maximum drop in voltage in the direct current part of the installation is between 3% and $I_{mp} \cdot V_{oc}$ (STC: standard test conditions).	Must be taken under consideration for the installation.	N/A
<b>11.3</b>	<b>Alternating current installation</b>	See below.	N/A

UTE C 15-712-1			
Clause	Requirement – Test	Result - Remark	Verdict
	For PV installations connected directly to the LV public distribution network, the maximum authorised drop in voltage between the a.c. terminals of the inverter and the point of delivery (NF C 14-100) is 3% at the nominal power of the inverter(s). It is recommended to limit this drop in voltage to 1% in order to be able to limit energy losses on the one hand and momentary disconnection of the inverter on the other, maintaining a margin between the average operating voltage of the inverter and the setting of its protection at maximum voltage.	Must be taken under consideration for the installation.	N/A

<b>12.</b>	<b>Disconnectors and circuit-breakers</b>	See below.	P
<b>12.1</b>	<b>General points</b>	Must be taken under consideration for the installation.	P
	To allow maintenance of PV inverters, disconnecting means must be provided by UPS, near both the DC side and the AC side.	Must be taken under consideration for the installation.	P
<b>12.2</b>	<b>Disconnectors</b>	See below.	P
	To allow maintenance work, a disconnecting device must be provided for inside or near the junctions boxes equipped with protective devices.	Must be taken under consideration for the installation.	P
<b>12.3</b>	<b>Emergency circuit-breakers</b>	Must be taken under consideration for the installation.	P
<b>12.3.1</b>	<b>General points</b>	See below.	P
	In accordance with the regulations set down in articles 463 and 536.3 of standard NF C 15-100, emergency circuit-breakers must be fitted on both a.c. and d.c. sides in order to cut off the electricity supply in the event of an unexpected hazard.	Must be taken under consideration for the installation.	P
<b>12.3.2</b>	<b>Emergency cut-off device of DC part</b>	See below.	P
	A cut-off device must be provided upstream from the inverter and its control shall be located Nearby thereof.	Must be taken under consideration for the installation.	P
	The actuation of the emergency disconnection device may be provided by a manual control or via a remote-controlled action.		N/A
<b>12.3.3</b>	<b>Emergency cut-off device of the AC part</b>	See below.	P
	The emergency disconnection can be ensured by manual control of the circuit-breaker or via a remote control action.	Must be taken under consideration for the installation.	P
<b>12.4</b>	<b>Disconnection for intervention of emergency services</b>		P

UTE C 15-712-1			
Clause	Requirement – Test	Result - Remark	Verdict
<b>12.4.1</b>	<b>General provisions</b>		<b>P</b>
	<p>If a break is required to allow the intervention of the emergency services, it must meet the following principles:</p> <ul style="list-style-type: none"> <li>- cut off all sources of electric energy</li> <li>- these devices are either switches or breakers or contactors, semiconductor devices not meet this requirement and each device must be in pole cut and simultaneous</li> <li>- cutting the PV generator circuit is made closer to the photovoltaic modules, and in any case upstream of the rooms and passages accessible to the occupants</li> </ul>	Must be taken under consideration for the installation.	P
<b>12.4.2</b>	<b>Additional provisions</b>		<b>N/A</b>
	If it is required to decrease to a value below 60 V dc the voltage of the PV generator circuit upstream of the required break in the general provisions of 12.4.1		N/A
	<p>The operational safety of these principles requires:</p> <p>a failsafe control;</p> <p>in the case of an electromechanical load cut off, the control must be carried out after opening of the support downstream switching device. Implementation</p> <p>these materials must respect the rules of double insulation (or reinforced insulation) imposed in this part of the plant and this for a voltage corresponding to the Uocmax chain tension.</p>		N/A

<b>13</b>	<b>Protection from surges emanating from the atmosphere or caused by operations</b>	See below.	P
<b>13.1</b>	<b>General points</b>	See below.	P
	The information contained in this chapter refers to overvoltage protection for photovoltaic installations connected to the network and complements standard NF C 15-100 and guide UTE C 61-740-52.	Compliance.	P
<b>13.1.1</b>	<b>Types of protection</b>	See below.	N/A
<b>13.1.1.1</b>	<b>Protection through equipotential bonding</b>	See below.	N/A

UTE C 15-712-1			
Clause	Requirement – Test	Result - Remark	Verdict
	As described in section 6.3, an equipotential bonding conductor must connect all the metal structures of the modules and the metal structures of the supports of the PV installation (including the metal cable runs) whether or not lightning conductors are present. This conductor must be connected to the earth.	All conductive parts of inverter case are connected to earth.	N/A
<b>13.1.1.2</b>	<b>Protection by lightning arresters</b>	See below.	N/A
	The installation conditions are described in 13.2.	Must be taken under consideration for the installation.	N/A
<b>13.2</b>	<b>Installation conditions for lightning arresters</b>	See below.	N/A
<b>13.2.1</b>	<b>Installation conditions for lightning arresterson a.c. side</b>	See below.	N/A
	The provisions of Articles 443 and 534 of the NF C 15-100 apply.	Must be taken under consideration for the installation.	N/A
<b>13.2.2</b>	<b>Installation conditions for lightning arresters on d.c. side</b>	See below.	N/A
<b>13.2.2.1</b>	<b>Installation without lightning conductor</b>	See below.	N/A
	The length L is the cumulative distance between the (s) inverter (s) and the channels of the entry points further away, considering each way (see Figure 8).	Must be taken under consideration for the installation.	N/A
<b>13.2.2.2</b>	<b>Installation with lightning conductor</b>	See below.	N/A
	The implementation of SPD dc generator side is mandatory	Must be taken under consideration for the installation.	N/A
<b>13.3</b>	<b>Overvoltage protection for installations without lightning conductor</b>	See below.	N/A
<b>13.3.1</b>	<b>Choice and installation of lightning arresters on a.c. side</b>	See below.	N/A
	If a lightning arrester is prescribed for the a.c. part of a PV installation connected to the public low-voltage distribution network, it is always installed in the panel nearest to the installation origin of the installation. If this lightning arrester is located more than 10 metres away from the inverter, a second lightning arrester must be installed near the latter.	Must be taken under consideration for the installation.	N/A
<b>13.3.2</b>	<b>Choice and installation of lightning arresters on d.c. side</b>	See below.	N/A

UTE C 15-712-1			
Clause	Requirement – Test	Result - Remark	Verdict
	If a lightning arrester is prescribed for the d.c. part of a PV installation, it is always installed in the panel nearest to the inverter. If one of the chains is located more than 10 metres away from the inverter, the installation of a second lightning arrester near the chains is recommended.	Must be taken under consideration for the installation.	N/A
<b>13.3.3</b>	<b>Choice of <math>I_n</math></b>	See below.	N/A
	The lightning arresters are type 2 with a minimum value for the nominal discharge current $I_n$ of 5 kA. A higher nominal discharge current than the required value will prolong the service life of the lightning arrester.	Must be taken under consideration for the installation.	N/A
<b>13.3.4</b>	<b>Choice of <math>I_{max}</math></b>	See below.	N/A
	This parameter is used to coordinate the energy of the lightning arresters: please refer to information from the manufacturer.	Must be taken under consideration for the installation.	N/A
<b>13.3.5</b>	<b>Choice of <math>U_p</math></b>	See below.	N/A
	The value of $U_p$ must be less than 80% of the surge withstand voltage of the equipment to be protected.	Must be taken under consideration for the installation.	N/A
<b>13.3.6</b>	<b>Choice of <math>U_{CPV}</math></b>	See below.	N/A
	The value of the maximum permissible voltage from the lightning arrester $U_{CPV}$ must be selected according to the maximum open-circuit voltage of the PV generator corresponding to the voltage $U_{ocSTC}$ specified by the manufacturers of the PV modules. The voltage $U_{CPV}$ must be greater than or equal to the maximum voltage $U_{ocMAX}$ of the photovoltaic generator. Whatever the protection methods of the lightning arrester, it must also withstand the maximum voltage $U_{ocMAX}$ between these live terminals (+ and - terminals) and the earth.	Must be taken under consideration for the installation.	N/A
<b>13.3.7</b>	<b>Choice of <math>I_{SCWPV}</math> and protection device associated with the lightning arrester</b>	See below.	N/A
	The lightning arrester must be fitted with an external disconnection device, if specified by the manufacturer; this assembly must be sized to function regardless of the current produced by the PV modules.	Must be taken under consideration for the installation.	N/A
<b>13.4</b>	<b>Additional regulations for surge protection for installations with a lightning conductor</b>	See below.	N/A
	The regulations are set out in guide UTE C 61-740-52.	Must be taken under consideration for the installation.	N/A

UTE C 15-712-1			
Clause	Requirement – Test	Result - Remark	Verdict
<b>14.</b>	<b>Choice and installation of equipment</b>	See below.	P
14.1	General points	See below.	P
	<p>The rated operating voltage of all the equipment of the d.c. part must be equal to or greater than the voltage UOCMAX.</p> <p>In the case of buildings with multiple occupation (for tertiary or residential use) with photovoltaic production in communal parts, the lines coming from the PV modules must be routed round the outside of private areas to the junction boxes for the chain/group located in the communal areas or in the buildings or the electrical service site dedicated to this purpose.</p> <p>The equipment installed outside must have a minimum degree of protection of IP44. The degree of protection against mechanical impacts must be at least IK07 in compliance with standard NF EN 62262 (C 20-015).</p> <p>It must be possible to carry out work on the removable equipment, devices and connections in the utmost safety.</p> <p>If a transformer is installed, the inverters and any general low-voltage panel must be installed close to the transformer in the same room or in adjoining rooms.</p> <p>The location of equipment (junction box(es), inverter(s), cabinets with protection devices and meter cabinets etc.) must comply with article 513.1 of standard NF C 15-100. Special regulations for residential buildings are given in article 771. The equipment, including the ducts etc., must be arranged so that they can be operated, inspected and serviced easily and their connections can be accessed.</p>	The inverter is rated IP65.	P
<b>14.2</b>	<b>Ducts etc.</b>	See below.	N/A
<b>14.2.1</b>	<b>Choice for the d.c. part</b>	See below.	P
	The ducts are sized in accordance with the regulations in standard NF C 15-100 on the basis of cables with reticulated polyethylene insulation.	Must be taken under consideration for the installation.	P
<b>14.2.2</b>	<b>Installation</b>	See below.	N/A
	The connections and the cables must be installed in a manner that will prevent any deterioration due to external influences. See the requirements set out in guide UTE C 15-520.	Must be taken under consideration for the installation.	P
<b>14.3</b>	<b>PV modules</b>	See below.	N/A

UTE C 15-712-1			
Clause	Requirement – Test	Result - Remark	Verdict
	The PV modules must comply with the standards in series NF EN 61730.	Must be taken under consideration for the installation.	N/A
<b>14.4</b>	<b>Inverters</b>	See below.	P
	The level of the current for the inverter must be based on $I_{mppSTC}$ .	Must be taken under consideration for the installation.	P
<b>14.5</b>	<b>Equipment</b>	See below.	P
	<p>All equipment installed in the d.c. part must be adapted for operation in direct current and be selected and installed in accordance with the manufacturer's instructions.</p> <p>Equipment installed in the d.c. part must be of the industrial type, in other words compliant with the NF EN 60947 series of standards.</p> <ul style="list-style-type: none"> <li>• The characteristics of switches, switch-disconnectors and fuse-combination units must conform to the operating category DC21B.</li> <li>• The characteristics of disconnectors must conform to the operating category DC20.</li> <li>• The characteristics of contactors must conform to the operating category DC1.</li> </ul>		P
<b>14.6</b>	<b>Equipment assemblies</b>	See below.	P
	<p>The direct current and alternating parts of the installation can be accommodated in the same panel if there is a physical separation of these two parts.</p> <p>For the d.c. part, it is imperative to protect all the connections or disconnection devices against accidental or unauthorised opening when live in accordance with 536.2.3 of standard NF C 15-100. To this end, a notice "Do not operate when live" must be placed inside the boxes or cabinets near these disconnection devices.</p> <p>Furthermore, in premises accessible to persons other than those with the requisite authorisation or qualification (BA4 or BA5):</p> <ul style="list-style-type: none"> <li>• The design or installation must be such that it is only possible to disassemble the connection devices with the aid of a tool;</li> <li>• Equipment that does not have an under load circuit-breaking feature must require the either the use of a key or tool or the direct operation of a device with an under load circuit-breaking feature.</li> </ul>	The PV input connectors can not be removed with out a aid of a tool. In addition there is a marking adjent the connectors with states "Do not operate when live"	P
<b>14.7</b>	<b>Connectors</b>	See below.	P

UTE C 15-712-1			
Clause	Requirement – Test	Result - Remark	Verdict
	In the d.c. part, the connectors used must comply with the standard NF EN 50521. To guarantee the quality of the connection and limit the risks of an electric arc that could spark a fire, each pair of male and female connectors to be assembled must be of the same type and the same brand.	The unit provides only one type and brand of connectors for DC with male and female plugs, which are not interchangeable. The plugs are according to EN 50521.	P
<b>14.8</b>	<b>Lightning arresters</b>		N/A
<b>14.8.1</b>	<b>Choice of lightning arresters</b>		N/A
	The lightning arresters installed in the a.c. part of the PV installation must comply with standard NF EN 61643-11.  The lightning arresters installed in the d.c. part of the PV installation must meet the requirements of guide UTE C 61-740-51.		N/A
<b>14.8.2</b>	<b>Installation of lightning arresters</b>		N/A
	Alternating current and direct current lightning arresters are installed in accordance with the regulations set out in guide UTE C 61-740-52.		N/A
<b>15</b>	<b>Markings</b>	See below.	P
<b>15.1</b>	<b>Identification of components</b>	See below.	P
	The main components comprising the photovoltaic installations must be identified and marked with clearly visible labels fixed permanently in accordance with the installation plans and diagrams:	The inverter provides permanent marking.	P
<b>15.2</b>	<b>Labelling</b>	See below.	P
	For safety reasons and to alert the different people carrying out work in and around the building (staff tasked with maintenance work, inspectors, public distribution network operators, emergency services, etc.), it is imperative that the presence of a photovoltaic installation on a building is indicated.	Compliance.	P
<b>15.2.1</b>	<b>Labelling on the a.c. part</b>	Must be taken under consideration for the installation.	N/A
<b>15.2.2</b>	<b>Labelling on the d.c. part</b>	See below.	N/A
	All the junction boxes (PV generator and PV groups) and d.c. ducts must carry a visible and permanent marking indicating that live parts within these boxes may remain under voltage even after the inverter has been disconnected on the direct current side.	Must be taken under consideration for the installation.	N/A
<b>15.3.2</b>	<b>Labelling on the inverter</b>	See below.	P



UTE C 15-712-1			
Clause	Requirement – Test	Result - Remark	Verdict
	All inverters must bear a marking indicating that before any work is carried out, the two sources of voltage must be isolated.	The unit is provided with the applicable marking	P

<b>16.</b>	<b>Technical file</b>	See below.	P
	<p>The technical file must include the following items drawn up in French:</p> <ul style="list-style-type: none"> <li>• A circuit diagram of the photovoltaic system;</li> <li>• The list of installed equipment mentioning the characteristics and references to the replacement parts (fuses, lightning arrester cartridges etc.);</li> <li>• An installation diagram for the various photovoltaic components and modules as well as the corresponding connections (ducts);</li> <li>• A description of the procedure for working on the photovoltaic system and safety instructions.</li> </ul>	The required information are stated in the manual.	P


<b>17.</b>	<b>Maintenance of photovoltaic installations</b>	See below.	N/A
<b>17.1</b>	<b>General points</b>	See below.	N/A
	The minimal technical maintenance work must be provided for during the life cycle of a photovoltaic installation to maintain or restore the installation to a state in which it can fulfil the function for which it was designed.	Must be taken under consideration for the installation.	N/A
<b>17.2</b>	<b>Levels and frequency of maintenance</b>	See below.	N/A
	<p>A distinction is made between the following three levels of maintenance comprising:</p> <ul style="list-style-type: none"> <li>• Conditional maintenance based on monitoring of the key parameters of the installation;</li> <li>• Precautionary maintenance carried out according to the prognoses extrapolated from the analysis and evaluation of the key parameters concerning the degradation of the asset (e.g. corrosion);</li> <li>• Systematic maintenance carried out at predetermined intervals and without a prior check of the state of the product or its constituent components.</li> </ul>	Must be taken under consideration for the installation.	N/A
<b>17.3</b>	<b>Technical areas covered during maintenance</b>	See below.	N/A

UTE C 15-712-1			
Clause	Requirement – Test	Result - Remark	Verdict
	A distinction is made between operations relating to the safety of persons and property, and actions relating to functional reliability.	Must be taken under consideration for the installation.	N/A

9	TABLE: Frequency monitoring test				P
Rating frequency: 50Hz, speed: 1 Hz/s					
For standard VDE 0126-1-1:2013/ VFR 2014					
UF/OF	Trip value [Hz]		Trip time [ms]		
No.	Measurement	Limitation	Measurement	Limitation	Remark
1	47.49	47.5±0.05	74	200	48.0Hz -> __47__ Hz
2	47.49		75	200	Delayed time: __510__ ms is considered.
3	47.49		69	200	
1	50.60	50.6±0.05	194	200	50.0Hz -> __51.0__ Hz
2	50.59		190	200	Delayed time: __610__ ms is considered.
3	50.61		190	200	

-End of test report-

**TEST REPORT**  
**DIN VDE 0126-1-1: 2013**  
**Automatic disconnection device between a generator**  
**and the public low-voltage grid**

Report Reference No. ....: 50225111 001 Attachment 1 Tested by (name + signature) .....: N/A Witnessed by (name + signature) ....: N/A Supervised by (name + signature) ...: N/A Approved by (name + signature).....: N/A Date of issue .....: See cover page
Testing Laboratory .....: TÜV Rheinland (Shenzhen) Co., Ltd. Address .....: 1F East & 2-4F, Cybio Technology Building No.1, No.16 Kejibei 2nd Road, High-Tech Industrial Park North Nanshan District, 518057, Shenzhen, China Testing location/ procedure.....: CBTL <input type="checkbox"/> TMP <input type="checkbox"/> WMT <input checked="" type="checkbox"/> SMT <input type="checkbox"/> RMT <input type="checkbox"/> CCATL <input type="checkbox"/> Testing location/ address .....: See page 4
Applicant's name .....: EAST Group Co., Ltd. Address .....: No.6 Northern Industry Road, Songshan Lake Sci.& Tech. industrial zone, Dongguan City, Guangdong province, China
Test specification: Standard .....: DIN VDE 0126-1-1(VDE V 0126-1-1): 2013-08 Test procedure .....: AK Non-standard test method.....: N/A
Test Report Form No.....: DIN VDE V 0126-1-1/2013 Test Report Form(s) Originator.....: TÜV Rheinland Group Master TRF .....: 2013-12 <b>Copyright © 2006 IEC System for Conformity Testing and Certification of Electrical Equipment (IECEE), Geneva, Switzerland. All rights reserved.</b> <b>This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.</b>
Test item description .....: Photovoltaic grid-connected inverter Trade Mark .....:  Manufacturer .....: As applicant Model/Type reference .....: See rating label and model list for detail Ratings .....: See rating label and model list for detail

<b>Testing procedure and testing location:</b>	
<input type="checkbox"/> <b>CB Testing Laboratory:</b>	See cover page
Testing location/ address .....	See cover page
<input type="checkbox"/> <b>Associated CB Test Laboratory:</b>	
Testing location/ address .....	
Tested by (name + signature) .....	See cover page .....
Approved by (+ signature) .....	See cover page .....
<input type="checkbox"/> Testing procedure: TMP	
Tested by (name + signature) .....	
Approved by (+ signature) .....	
Testing location/ address .....	
<input type="checkbox"/> Testing procedure: WMT	
Tested by (name + signature) .....	
Witnessed by (+ signature) .....	
Approved by (+ signature) .....	
Testing location/ address .....	
<input type="checkbox"/> Testing procedure: SMT	
Tested by (name + signature) .....	
Approved by (+ signature) .....	
Supervised by (+ signature) .....	
Testing location/ address .....	
<input type="checkbox"/> Testing procedure: RMT	
Tested by (name + signature) .....	
Approved by (+ signature) .....	
Supervised by (+ signature) .....	
Testing location/ address .....	

**List of Attachments (including a total number of pages in each attachment):**

N/A

**Summary of testing:**

The test was performed on the model EA6KSI and valid for other models: EA2KSI, EA2.5KSI, EA3KSI-D, EA3KSI, EA3.68KSI, EA4KSI, EA4.6KSI, EA5KSI.

**Tests performed (name of test and test clause):****Testing location:**

Clause	Test description
<input checked="" type="checkbox"/> 6.1	Functional Safety
<input checked="" type="checkbox"/> 6.2	Connection Condition
<input checked="" type="checkbox"/> 6.3	Voltage Monitoring
<input checked="" type="checkbox"/> 6.4	Frequency Monitoring
<input checked="" type="checkbox"/> 6.5	Direct Current Monitoring
<input checked="" type="checkbox"/> 6.6	Detection Of Islanding Operation
<input checked="" type="checkbox"/> Additional	Requirements for in photovoltaic inverter integrated disconnecter

**CCIC Southern Electronic Product Testing(Shenzhen) Co., Ltd.**

Electronic Testing Building, Shahe Road 43 Xili,  
Nanshan District, Shenzhen, China

Remark:

**Copy of marking plate:**

See test report 50225111 001.

Equipment mobility .....	: <input type="checkbox"/> movable <input type="checkbox"/> hand-held <input type="checkbox"/> stationary <input checked="" type="checkbox"/> fixed <input type="checkbox"/> transportable <input type="checkbox"/> for building-in
Connection to the mains.....	: <input type="checkbox"/> pluggable equipment <input type="checkbox"/> direct plug-in <input checked="" type="checkbox"/> permanent connection <input type="checkbox"/> for building-in
Environmental category.....	: <input checked="" type="checkbox"/> outdoor <input type="checkbox"/> indoor <input type="checkbox"/> indoor conditional unconditional
Operating condition .....	: <input checked="" type="checkbox"/> continuous <input type="checkbox"/> short-time <input type="checkbox"/> intermittent
Over voltage category mains.....	: <input type="checkbox"/> OVC I <input type="checkbox"/> OVC II <input checked="" type="checkbox"/> OVC III <input type="checkbox"/> OVC IV
Over voltage category PV .....	: <input type="checkbox"/> OVC I <input checked="" type="checkbox"/> OVC II <input type="checkbox"/> OVC III <input type="checkbox"/> OVC IV
Mains supply tolerance (%).....	: According to specified supply range
Tested for IT power systems .....	: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
IT testing, phase-phase voltage (V) .....	: N/A
Class of equipment .....	: <input checked="" type="checkbox"/> Class I <input type="checkbox"/> Class II <input type="checkbox"/> Class III <input type="checkbox"/> Not classified
Mass of equipment (kg).....	: See model list
Pollution degree .....	: <input type="checkbox"/> PD 1 <input type="checkbox"/> PD 2 <input checked="" type="checkbox"/> PD 3 (outside)
IP protection class .....	: IP65
<b>Possible test case verdicts:</b>	
- test case does not apply to the test object.....	: N/A
- test object was not evaluated for the requirement.....	: N/E
- test object does meet the requirement.....	: Pass (P)
- test object does not meet the requirement.....	: Fail (F)
<b>Testing:</b>	
Date of receipt of test items .....	: See cover page
Date(s) of performance of tests .....	: See cover page
<b>General remarks:</b>	
"(see Attachment #)" refers to additional information appended to the report.	
"(see appended table)" refers to a table appended to the report.	
The tests results presented in this report relate only to the object tested.	
This report shall not be reproduced except in full without the written approval of the testing laboratory.	
List of test equipment must be kept on file and available for review.	
Additional test data and/or information provided in the attachments to this report.	
Throughout this report a <input type="checkbox"/> comma / <input checked="" type="checkbox"/> point is used as the decimal separator.	
<b>Manufacturer's Declaration per sub-clause 6.2.5 of IEC60335-1:</b>	
<b>The application for obtaining a CB Test Certificate includes more than one factory location and a declaration from the Manufacturer stating that the sample(s) submitted for evaluation is (are) representative of the products from each factory has been provided :</b>	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> Not applicable
<b>When differences exist; they shall be identified in the General product information section.</b>	
<b>Name and address of factory (ies) :</b>	<b>EAST Group Co., Ltd.</b> NO.6 NORTHERN INDUSTRY No.6 Northern Industry



**General product information:**

See report 50225111 001.

Protection function of PGU:

1. PV array insulation resistance detecting.
2. Residual current monitoring.
3. Over & under grid voltage protection.
4. Over & under grid frequency protection.
5. Anti-islanding protection.
6. Over DC injection current protection.
7. NS & NA protection redundantly.
8. Relays used in series for grid auto-disconnection devices.
9. Short-circuit protection rely on external circuits break which was specified in installation manual.
10. Over temperature derating and protection.
11. Over current protection.
12. Relay function self-check.
13. RCM function self-check.

Throughout the test report following abbreviations may be used:

• cl	clearance	• int	internal distance
• dcr	creepage distance	• o-c	open-circuit
• dti	distance through insulation	• o-l	overload
• PCE	Power Conversion Equipment	• s-c	short-circuit
• BI	basic insulation	• SI	supplementary insulation
• DI	double insulation	• RI	reinforced insulation



<b>This test report includes the following Appendixes:</b>		
<b>Appendix No.</b>	<b>Description</b>	<b>Page(s)</b>
A	TABLE: Insulation resistance measurement	1
B	TABLE: Residual current monitoring test	2

DIN VDE 0126-1-1: 2013			
Clause	Requirement – Test	Result - Remark	Verdict
<b>4</b>	<b>Requirements</b>		<b>P</b>
4.0	General		P
	The disconnection device must disconnect the generator unit from the grid on the AC side due to <ul style="list-style-type: none"> <li>- voltage and/or frequency fluctuations in the low voltage grid</li> <li>- d.c. feed into the low voltage grid</li> <li>- unintended islanding and</li> <li>- intended islanding with standby generating units</li> </ul>	The disconnection device of relay could automatically disconnect from grid, switch off and show the fault status in the event of faults from grid.	P
	by means of two switches arranged in series.	Two switches in series.	P
4.1	Functional safety	See descriptions of PGU protection function in page 4. Refer to subclause 6.1.	P
4.1.1	Safety against single faults	NS protection: single fault safe	P
	The switches must fulfill the requirements of single fault according to VDE-AR-N 4105: 2011-08, A.6.		P
4.1.2	Disconnection equipment		P
	The disconnection equipment must fulfill the requirements according to DIN EN 62109-2:2012-04, 4.4.4.15.2 in case of one integrated in a PV inverter and the requirements according to VDE-AR-N 4105:2011-08, 6.4 in all other cases.	Two all-phases relays in series as reliable grid disconnection interface switch.	P
4.2	Connection condition	See subclause 6.2	P
	The connection, reconnection after a grid fault and the reconnection after a short interruption must act according to VDE-AR-N 4105: 2011-08, 8.3.1.		P
4.3	Voltage monitoring	See subclause 6.3	P
4.3.1	Voltage decrease $U <$		P
	The disconnection caused by a slow voltage drop must act according to VDE-AR-N 4105: 2011-08, 6.5.1.		P
4.3.2	Voltage increase $U >>$		P
	The disconnection caused by a voltage increase must act according to VDE-AR-N 4105: 2011-08, 6.5.1 and 6.5.2.		P
4.3.3	Voltage increase $U >$		P
	The disconnection caused by a slow voltage increase (10-min-average) must act according to VDE-AR-N 4105: 2011-08, 6.5.1 and 6.5.2.		P
4.4	Frequency monitoring	See subclause 6.4.	P

DIN VDE 0126-1-1: 2013			
Clause	Requirement – Test	Result - Remark	Verdict
	The disconnection caused by a frequency decrease or frequency increase must act according to VDE-AR-N 4105: 2011-08, 6.5.1 and 6.5.2.		P
4.5	Direct current monitoring	See subclause 6.6.	P
	A direct current feed to the low voltage grid due to a defective generator operation must lead to a disconnection within 0.2 s. For this, either the malfunction itself or a measured d.c. component of the current of more than 1 A can serve as a criterion.	Complies.	p
4.6	Detection of islanding	See subclause 6.6.	P
	The disconnection caused by a detection of an unintentionally islanding operation must act according to VDE-AR-N 4105: 2011-08, 6.5.1 and 6.5.3.	Complies.	P
4.7	Identification	Complies.	P
	A generator with automatic switching must have the outer visible claim "VDE V 0126-1-1". It's can be by e.g. - the labelling or - a showing on the display of switches or - a separate marking act.	Complies.	P
4.8	Requirements for in photovoltaic inverter integrated switches	Complies.	P
	The requirements according to DIN EN 62109-2:2012-04, 4.8, on the residual current monitoring and on the isolation monitoring of PV generators must be fulfilled.	See subclause Annex B	P

<b>5</b>	<b>General requirements</b>		<b>P</b>
	It's the limitation according to DIN EN 61000-6-3 regarding to the radio disturbance to compliant. For the immunity are the test disturb variant according to DIN EN 61000-6-2 to be used.	Complied.	P

<b>6</b>	<b>Type test</b>		<b>P</b>
6.0	General		P
	The following tests shall apply, unless otherwise mentioned, for integrated and separate switches. A separate switch is together tested with a suitable feeder. This is to ensure, that the disconnection signal isn't made from the feeder but from the switch.	The integrated switch is together tested with suitable feeder.	P
6.1	Functional safety		P

DIN VDE 0126-1-1: 2013			
Clause	Requirement – Test	Result - Remark	Verdict
	The test of the single fault safety and the fault indication with followed disconnection performs according to DIN VDE V 0124-100:2012-07, 5.4.5.2.	Two DSP controller for controlling grid isconnection, with two all-phases relay in series as reliable grid disconnection interface switch, to assure single fault safe of NS protection function. See appended table, failures evaluation and risk analysis in case of single fault conditions, even software failure.	P
6.2	Connection condition	See appendix table 6.2	P
	The test of connection and reconnection performed according to DIN VDE V 0124-100:2012-07, 5.5.1 and 5.5.2.		P
6.3	Voltage monitoring	See appendix table 6.3	P
	The test of voltage monitoring performed according to DIN VDE V 0124-100:2012-07, 5.4.5.3.		P
6.4	Frequency monitoring	See appendix table 6.4	P
	The test of frequency monitoring performed according ot DIN VDE V 0124: 2012-07, 5.4.5.4		P
6.5	DC current monitoring	See appendix table 6.5	P
	The test of the disconnection as a result of direct current feed in perform optional according to a) or b): a) In the measure circuit of the switch (e.g. current transducer, sampling resister) is a direct current of 1A injected. The disconnection must within 0,2s acted. b) By a fault simulation is the measure ensure directly, if a disturbed device running with a direct part of current more than 1 A to disconnection in 0,2s result.		P
6.6	Detection of islanding	See appendix table 6.6	P
	The test of disconnection as result of unintentional islanding running act according to DIN VDE V 0124-100:2012-07, 5.4.6.		P
<b>7</b>	<b>Routine test</b>	Complies.	P
	Each manufacturer execute the routine test about the safety related parameter before delivery of an automatic switch.		P

---

8	Specification of the device	Complies.	P
	Initial and periodic testing of the automatic disconnection of the routine test may also be omitted. If the automatic disconnection device running as a standalone device, it may not in the TN-C system be used. It is to create a TN-CS system in this area.		P

6.1		TABLE: Functional Safety						P
No.	Component no.	Fault	Test voltage (V)	Test time	Fuse no.	Fuse current (A)	Result	
1.	PV1 voltage monitoring defect R241	o-c	400	3min	--	--	No message. PV inverter disconnected from grid immediately. No damaged, no hazard.	
2.	PV1 voltage monitoring defect C235	s-c	400	3min	--	--	No message. PV inverter disconnected from grid immediately. No damaged, no hazard.	
3.	Boost1 circuit monitoring defect R244	o-c	400	3min	--	--	No message. PV inverter run normally. (PV inverter restart. Error message: PV Curr Channel Err1) No damaged, no hazard.	
4.	Boost1 circuit monitoring defect R245	o-c	400	3min	--	--	No message. PV inverter run normally . (PV inverter restart. Error message: PV Curr Channel Err1) No damaged, no hazard.	
5.	PV2 voltage monitoring defect R248	o-c	400	3min	--	--	Error message: PV Above BUS Err PV inverter disconnected from grid immediately. No damaged, no hazard.	
6.	PV2 voltage monitoring defect C244	s-c	400	3min	--	--	No message. PV inverter disconnected from grid immediately. No damaged, no hazard.	
7.	BUS voltage monitoring defect R252	o-c	400	3min	--	--	Error message: Boost SelfChk Err1 PV inverter disconnected from grid immediately. No damaged, no hazard.	
8.	BUS voltage monitoring defect C246	s-c	400	3min	--	--	Error message: BUS Volt Low Err, PV Above BUS Err PV inverter disconnected from grid immediately. No damaged, no hazard.	

9.	BUS overvoltage protection defect R259	o-c	400	3min	--	--	Error message: BUS Over VoltHW Err PV inverter disconnected from grid immediately. No damaged, no hazard.
10.	Boost2 circuit monitoring defect R476	s-c	400	3min	--	--	Error message: PV Over Curr HWErr, PV Curr Channel Err2. PV inverter disconnected from grid immediately. No damaged, no hazard.
11.	Boost2 circuit monitoring defect C247	s-c	400	3min	--	--	Error message: PV Curr Channel Err2. PV inverter disconnected from grid immediately. No damaged, no hazard.
12.	ISO monitoring defect R227	o-c	400	3min	--	--	No message. PV inverter runs normally . No damaged, no hazard.
13.	ISO monitoring defect R81	o-c	400	3min	--	--	No message. PV inverter runs normally . (PV inverter restart. Error message: ISO Err) No damaged, no hazard.
14.	ISO monitoring defect C239	s-c	400	3min	--	--	No message. PV inverter runs normally . (PV inverter restart. Error message: ISO Err) No damaged, no hazard.
15.	INV voltage monitoring defect R457	s-c	400	3min	--	--	Error message: Output Relay Err. PV inverter disconnected from grid immediately. No damaged, no hazard.
16.	INV voltage monitoring defect R275	o-c	400	3min	--	--	Error message: Output Relay Err. PV inverter disconnected from grid immediately. No damaged, no hazard.
17.	Grid voltage monitoring(MCU) defect R470	s-c	400	3min	--	--	Error message: DCI High Err, SMCU Grid Volt Err. PV inverter disconnected from grid immediately. No damaged, no hazard.

18.	Grid voltage monitoring(MCU) defect C263	s-c	400	3min	--	--	Error message: SMCU Grid Volt Err. PV inverter disconnected from grid immediately. No damaged, no hazard.
19.	Grid voltage monitoring(DSP) defect R290	o-c	400	3min	--	--	Error message: Grid Volt Loss Err. PV inverter disconnected from grid immediately. No damaged, no hazard.
20.	Grid frequency monitoring defect R293	o-c	400	3min	--	--	Error message: Grid Under Freq Err2. PV inverter disconnected from grid immediately. No damaged, no hazard.
21.	Grid frequency monitoring defect R172	o-c	400	3min	--	--	No message. PV inverter runs normally. (PV inverter restart. Error message: SMCU Grid Freq Err) No damaged, no hazard.
22.	AC current monitoring defect R308	o-c	400	3min	--	--	Error message: Inv Over Curr HWErr, AD Inv Curr Channel Err. PV inverter disconnected from grid immediately. No damaged, no hazard.
23.	DCI monitoring defect R306	o-c	400	3min	--	--	Error message: DCI High Err. PV inverter disconnected from grid immediately. No damaged, no hazard.
24.	Earth monitoring defect R273	o-c	400	3min	--	--	No message. PV inverter runs normally. No damaged, no hazard.
25.	Earth monitoring defect R283	o-c	400	3min	--	--	No message. PV inverter runs normally. No damaged, no hazard.
26.	Leakage current monitoring defect R307	o-c	400	3min	--	--	Error message: Leak Curr Err. PV inverter disconnected from grid immediately. No damaged, no hazard.
27.	Leakage current monitoring defect R312	o-c	400	3min	--	--	Error message: Leak Curr Err. PV inverter disconnected from grid immediately. No damaged, no hazard.



28.	Leakage current monitoring defect C290	s-c	400	3min	--	--	Error message: Leak Curr Err. PV inverter disconnected from grid immediately. No damaged, no hazard.
29.	MCU controller defect CY4	s-c	400	3min	--	--	No message. PV inverter runs normally. (PV inverter is on standby, when it restart.) No damaged, no hazard.
30.	MCU controller defect SPISTEB	o-c	400	3min	--	--	No message. PV inverter runs normally. (PV inverter is on standby, when it restart.) No damaged, no hazard.
31.	MCU controller defect SPISMOB	o-c	400	3min	--	--	No message. PV inverter runs normally. (PV inverter is on standby, when it restart.) No damaged, no hazard.
32.	MCU controller defect SPISMIB	o-c	400	3min	--	--	No message. PV inverter runs normally. (PV inverter is on standby, when it restart.) No damaged, no hazard.
33.	MCU controller defect SPICKLB	o-c	400	3min	--	--	No message. PV inverter runs normally. (PV inverter is on standby, when it restart.) No damaged, no hazard.
34.	Reference power supply defect C150	s-c	400	3min	--	--	Error message: PV Over Volt Err, Ambient Over Temp Err, Grid Over Volt Err2. PV inverter disconnected from grid immediately. No damaged, no hazard.
35.	MCU power supply defect C227	s-c	400	3min	--	--	PV inverter disconnected from grid immediately. Q1, Q2, Q5, Q6 and K1, K2, K4 has be damaged, no hazard.
36.	MCU power supply defect C120	s-c	400	3min	--	--	PV inverter disconnected from grid immediately. Q1, Q2, Q5, Q6 and K1, K2, K4 has be damaged, no hazard.









37.	DSP controller defect CY3	s-c	400	3min	--	--	PV inverter disconnected from grid immediately. Q3, Q4 and K1, K2, K3, K4 has been damaged, no hazard.
38.	Relay defect RELAY1 (1-2pin)	s-c before start up	400	3min	--	--	Error message: Output Relay Err. PV inverter does not start up. No damaged, no hazard.
39.	Relay defect RELAY2 (1-2pin)	s-c before start up	400	3min	--	--	Error message: Output Relay Err. PV inverter does not start up. No damaged, no hazard.
40.	Relay defect RELAY3 (1-2pin)	s-c before start up	400	3min	--	--	Error message: Output Relay Err. PV inverter does not start up. No damaged, no hazard.
41.	Relay defect RELAY4 (1-2pin)	s-c before start up	400	3min	--	--	Error message: Output Relay Err. PV inverter does not start up. No damaged, no hazard.
42.	Earth1 monitoring defect R338	s-c before start up	400	3min	--	--	No message. PV inverter can start up. No damaged, no hazard.
43.	Earth1 monitoring defect R380	o-c before start up	400	3min	--	--	No message. PV inverter can start up. No damaged, no hazard.
44.	Earth1 monitoring defect R53	o-c before start up	400	3min	--	--	No message. PV inverter can start up. No damaged, no hazard.
45.	Earth1 monitoring defect R384	s-c before start up	400	3min	--	--	No message. PV inverter can start up. No damaged, no hazard.
46.	Earth2 monitoring defect R335	s-c before start up	400	3min	--	--	No message. PV inverter can start up. No damaged, no hazard.
47.	Earth2 monitoring defect R125	o-c before start up	400	3min	--	--	No message. PV inverter can start up. No damaged, no hazard.
48.	Earth2 monitoring defect R336	o-c before start up	400	3min	--	--	No message. PV inverter can start up. No damaged, no hazard.

49.	Earth2 monitoring defect R337	s-c before start up	400	3min	--	--	No message. PV inverter can start up. No damaged, no hazard.
50.	ISO monitoring defect R166	s-c before start up	400	3min	--	--	No message. PV inverter can start up. No damaged, no hazard.
51.	ISO monitoring defect R104	o-c before start up	400	3min	--	--	No message. PV inverter can start up. No damaged, no hazard.
52.	ISO monitoring defect R150	s-c before start up	400	3min	--	--	No message. PV inverter can start up. No damaged, no hazard.
53.	ISO monitoring defect R151	o-c before start up	400	3min	--	--	No message. PV inverter can start up. No damaged, no hazard.
54.	ISO monitoring defect R141	o-c before start up	400	3min	--	--	Error message: ISO Err. PV inverter does not start up. No damaged, no hazard.
55.	Vpv1 sampling defect R83	s-c	400	3min	--	--	Error message: PV Above BUS Err. PV inverter disconnected from grid immediately. No damaged, no hazard.
56.	Vpv1 sampling defect R77	o-c	400	3min	--	--	No message. PV inverter disconnected from grid immediately. No damaged, no hazard.
57.	Vpv2 sampling defect R84	o-c	400	3min	--	--	No message. PV inverter disconnected from grid immediately. No damaged, no hazard.
58.	Vpv2 sampling defect R88	s-c	400	3min	--	--	Error message: PV Above BUS Err. PV inverter disconnected from grid immediately. No damaged, no hazard.
59.	Vbus sampling defect R93	s-c	400	3min	--	--	No message. PV inverter run normally. No damaged, no hazard.

60.	Vbus sampling defect R89	o-c	400	3min	--	--	Error message: BUS Volt Low Err. PV inverter disconnected from grid immediately. No damaged, no hazard.
61.	Vac sampling defect R99	s-c	400	3min	--	--	No message. PV inverter run normally (PV inverter restart. Error message: Inv SelfChk Err) No damaged, no hazard.
62.	Vac sampling defect R103	s-c	400	3min	--	--	Error message: Output Relay Err. PV inverter disconnected from grid immediately. No damaged, no hazard.
63.	Vac sampling defect R97	o-c	400	3min	--	--	No message. PV inverter run normally (PV inverter restart. Error message: Output Relay Err) No damaged, no hazard.
64.	Vac sampling defect R101	o-c	400	3min	--	--	No message. PV inverter run normally (PV inverter restart. Error message: Output Relay Err) No damaged, no hazard.
65.	Vgrid sampling (DSP) defect R119	s-c	400	3min	--	--	Error message: DCI High Err, Grid Over Volt Err1. PV inverter disconnected from grid immediately. No damaged, no hazard.
66.	Vgrid sampling (DSP) defect R123	s-c	400	3min	--	--	Error message: DCI High Err. PV inverter disconnected from grid immediately. No damaged, no hazard.
67.	Vgrid sampling (DSP) defect R116	o-c	400	3min	--	--	Error message: Grid Volt Loss Err, DCI High Err. PV inverter disconnected from grid immediately. No damaged, no hazard.
68.	Vgrid sampling (DSP) defect R120	o-c	400	3min	--	--	Error message: DCI High Err. PV inverter disconnected from grid immediately. No damaged, no hazard.

69.	Vgrid sampling (MCU) defect R126	s-c	400	3min	--	--	No message. PV inverter run normally. No damaged, no hazard.
70.	Vgrid sampling (MCU) defect R337	s-c	400	3min	--	--	No message. PV inverter run normally. No damaged, no hazard.
71.	Vgrid sampling (MCU) defect R124	o-c	400	3min	--	--	No message. PV inverter run normally (PV inverter restart. Error message: SMCU Grid Volt Err) No damaged, no hazard.
72.	Vgrid sampling (MCU) defect R128	o-c	400	3min	--	--	No message. PV inverter run normally. No damaged, no hazard.
73.	C91	s-c	400	3min	--	--	No message. PV inverter disconnected from grid immediately. No damaged, no hazard.
74.	D38	s-c	300	3min	--	--	PV inverter disconnected from grid immediately. Q7, D1 has be damaged, no hazard.
75.	CT1 AGND	o-c	400	3min	--	--	No message. PV inverter run normally (PV inverter restart. Error message: PV Curr Channel Err1) No damaged, no hazard.
76.	CT2 AGND	o-c	400	3min	--	--	No message. PV inverter run normally (PV inverter restart. Error message: PV Curr Channel Err2) No damaged, no hazard.
77.	Q7(D-S)	s-c	300	10min	--	--	PV inverter disconnected from grid immediately. Q7 has be damaged, no hazard.
78.	C84	s-c	400	3min	--	--	PV inverter disconnected from grid immediately. C84 has be damaged, no hazard.

79.	C166	s-c	400	3min	--	--	PV inverter disconnected from grid immediately. Q1, Q2, Q5, Q6 has been damaged, no hazard.
80.	Q1(D-S)	s-c	400	10min	--	--	PV inverter disconnected from grid immediately. Q1, Q5 has been damaged, no hazard.
81.	Q1(D-G)	s-c	400	10min	--	--	PV inverter disconnected from grid immediately. Q1, Q5has be damaged, no hazard.
82.	Q6(D-G)	s-c	400	10min	--	--	PV inverter disconnected from grid immediately. Q2, Q6 has be damaged, no hazard.
83.	C504	s-c	400	3min	--	--	PV inverter disconnected from grid immediately. D501, R503 has be damaged, no hazard.
84.	Q500(D-S)	s-c	400	10min	--	--	PV inverter disconnected from grid immediately. R503, D501 has be damaged, no hazard.
85.	Q500(D-G)	s-c	400	10min	--	--	PV inverter disconnected from grid immediately. R503, D501, Q500 has be damaged, no hazard.
86.	C500	s-c	400	3min	--	--	PV inverter disconnected from grid immediately. R153 has be damaged, no hazard.
87.	C590	s-c	400	3min	--	--	PV inverter disconnected from grid immediately. R157has be damaged, no hazard.
88.	C44	s-c	400	3min	--	--	PV inverter disconnected from grid immediately. No damaged, no hazard.
89.	C63	s-c	400	3min	--	--	PV inverter disconnected from grid immediately. No damaged, no hazard.
90.	R530	o-c	400	3min	--	--	PV inverter disconnected from grid immediately. No damaged, no hazard.

6.2	TABLE: Reconnection condition				P
Conditions					
Reconnection	<input type="checkbox"/> Yes/ <input checked="" type="checkbox"/> No	<input checked="" type="checkbox"/> Yes/ <input type="checkbox"/> No	<input type="checkbox"/> Yes/ <input checked="" type="checkbox"/> No	<input checked="" type="checkbox"/> Yes/ <input type="checkbox"/> No	
Conditions					
Reconnection	<input type="checkbox"/> Yes/ <input checked="" type="checkbox"/> No	<input checked="" type="checkbox"/> Yes/ <input type="checkbox"/> No	<input type="checkbox"/> Yes/ <input checked="" type="checkbox"/> No	<input checked="" type="checkbox"/> Yes/ <input type="checkbox"/> No	

6.3	TABLE: line to neutral voltage monitoring					P
Rated voltage $U_n$ : 230V						
No.	Set value [V]	Threshold value [V]			Limitation VDE 4105	Remark
		L1	L2	L3		
1	184	185	--	--	80% $U_n$ ±1%	Decreasing value ramp of 0.1V.
2		185	--	--		
3		185	--	--		
1	264.5	265	--	--	110% $U_n$ - 115% $U_n$ ±1%	Increasing value ramp of 0.1V.
2		265	--	--		
3		264	--	--		

UV / OV	Trip time [ms]			
	Measurement			Limitation VDE 4105
	L1	L2	L3	
Un to 77%Un	115	--	--	200
	115	--	--	200
	117	--	--	200
Un to 118%Un	120	--	--	200
	125	--	--	200
	126	--	--	200

Rated: 230Vac, 50Hz. Recover time

6.3	TABLE: over voltage protection as sliding 10-min-average value					P
	Rated voltage Un: 230V					
No.	U <sub>start</sub> [V]	U <sub>end</sub> [V]	Limitation T [min]	Trigger time [min]	Recover time [s]	
1	230	259	10	7min58s	164	
2	230	248.0	No disconnected	No disconnected	N/A	
3	244.0	262.0	5	5min41s	164	
Note:						

6.4	TABLE: Frequency monitoring test					P
	Rating frequency: 50Hz, speed: 1 Hz/s					
UF/O F	Trip value [Hz]		Trip time [ms]			
No.	Measurement	Limitation	Measurement	Limitation	Remark	
1	47.49	47.5	74	200	48.0Hz -> _47_Hz Delayed time: __510__ms is considered.	
2	47.49		75	200		
3	47.49		69	200		
1	51.50	51.5	136	200	51.0Hz -> __52__Hz Delayed time: __510__ms is considered.	
2	51.50		127	200		
3	51.50		132	200		
Note:						



6.5	TABLE: DC current monitoring test		P
DC current $\geq 1A$	Trip time [ms]		
	Measurement	Limitation	
$I_D \geq 1A$			
L1 Phase	145	200	
L2 Phase	--	--	
L3 Phase	--	--	
$I_D \leq -1A$			
L1 Phase	134	200	
L2 Phase	--	--	
L3 Phase	--	--	
Note: 100% output power			

6.6	TABLE: Detection of island operation test			P	
Rated voltage: 230V/N/PE					
Test Condition		Trip time			
P/Pn	<b>100%</b>	Measurement [ms]		Limit [ms]	
RLC Load		L1	L2		L3
P, P <sub>Q</sub> - 5%		185	--	--	5000
P, P <sub>Q</sub> - 4%		167	--	--	5000
P, P <sub>Q</sub> - 3%		164	--	--	5000
P, P <sub>Q</sub> - 2%		169	--	--	5000
P, P <sub>Q</sub> - 1%		169	--	--	5000
<b>P, P<sub>Q</sub></b>		177	--	--	5000
P, P <sub>Q</sub> + 1%		173	--	--	5000
P, P <sub>Q</sub> + 2%		152	--	--	5000
P, P <sub>Q</sub> + 3%		162	--	--	5000
P, P <sub>Q</sub> + 4%		136	--	--	5000
P, P <sub>Q</sub> + 5%		152	--	--	5000

Test Condition		Trip time			
P/Pn	<b>50%</b>	Measurement [ms]		Limit [ms]	
RLC Load		L1	L2		L3
P, P <sub>Q</sub> - 5%		151	--	--	5000
P, P <sub>Q</sub> - 4%		152	--	--	5000

P, P <sub>Q</sub> - 3%	148	--	--	5000
P, P <sub>Q</sub> - 2%	154	--	--	5000
P, P <sub>Q</sub> - 1%	141	--	--	5000
<b>P, P<sub>Q</sub></b>	146	--	--	5000
P, P <sub>Q</sub> + 1%	164	--	--	5000
P, P <sub>Q</sub> + 2%	162	--	--	5000
P, P <sub>Q</sub> + 3%	150	--	--	5000
P, P <sub>Q</sub> + 4%	146	--	--	5000
P, P <sub>Q</sub> + 5%	149	--	--	5000

Test Condition		Trip time			Limit [ms]
P/Pn	25%	Measurement [ms]			
RLC Load		L1	L2	L3	
P, P <sub>Q</sub> - 5%		151	--	--	5000
P, P <sub>Q</sub> - 4%		157	--	--	5000
P, P <sub>Q</sub> - 3%		160	--	--	5000
P, P <sub>Q</sub> - 2%		145	--	--	5000
P, P <sub>Q</sub> - 1%		149	--	--	5000
<b>P, P<sub>Q</sub></b>		160	--	--	5000
P, P <sub>Q</sub> + 1%		145	--	--	5000
P, P <sub>Q</sub> + 2%		126	--	--	5000
P, P <sub>Q</sub> + 3%		134	--	--	5000
P, P <sub>Q</sub> + 4%		141	--	--	5000
P, P <sub>Q</sub> + 5%		143	--	--	5000

Note:

Additional A	TABLE: Insulation resistance measurement					P
Conditions	Measurement [I.F. / N.O.]					Identification
	PV / DC Supply Voltage [Vdc]					
	V <sub>mpp</sub> lowest	1/4V <sub>mpp</sub>	1/2 V <sub>mpp</sub>	3/4 V <sub>mpp</sub>	V <sub>mpp</sub> highest	
PV+ to PE: 18[kΩ]	I.F	I.F	I.F	I.F	I.F	I.F.: Isolation Fault N.O.: Normal Operation
PV- to PE: 18[kΩ]	I.F	I.F	I.F	I.F	I.F	
PV+ to PE: 22[kΩ]	N.O.	N.O.	N.O.	N.O.	N.O.	
PV- to PE: 22[kΩ]	N.O.	N.O.	N.O.	N.O.	N.O.	
Note: Array Insulation Resistance Threshold Value $R = 20$ [kΩ] (Should be larger than $R = V_{MAX PV} / 30mA$ .) The accuracy of resistance measurement $\Delta R = 2$ [kΩ] (the value declared by manufacturer)						

Additional B	TABLE: Residual current trip value test		P
Test Conditions	Steadily Residual current threshold value		
	Measurement [mA]		Limitation [mA]
	U <sub>N</sub>		
PV+ to Neutral	280.68		300
	277.92		300
	280.19		300
	278.13		300
	280.53		300
PV- to Neutral	279.29		300
	280.31		300
	277.77		300
	281.27		300
	277.53		300
Note:			

Additional B	TABLE: Residual current monitoring test		P
Conditions	Trigger disconnection maximum time		
	Measurement [ms]	Limit [ms]	
Sudden residual current ≥ 30mA			
PV- to Neutral	158.4	300	
	159.2	300	
	170.8	300	
	166.4	300	
	170.8	300	
PV+ to Neutral	165.5	300	
	171.1	300	
	155.1	300	
	158.3	300	
	169.4	300	
Sudden residual current ≥ 60mA			
PV- to Neutral	19.6	150	
	11.6	150	

	26.2	150
	24.4	150
	37.4	150
PV+ to Neutral	102.2	150
	44.6	150
	53.8	150
	58.6	150
	57.8	150
Sudden residual current $\geq 150\text{mA}$		
PV- to Neutral	16.4	40
	23.0	40
	19.0	40
	15.0	40
	21.6	40
PV+ to Neutral	7.7	40
	14.6	40
	13.6	40
	26.3	40
	27.2	40
Note: 100% output power and Vmppmax input voltage		

- End of test report -

Product:

Grid-tied PV Inverter

Type:

EA2KSI, EA2.5KSI, EA3KSI, EA3KSI-D, EA3.68KSI,  
EA4KSI, EA4.6KSI, EA5KSI, EA6KSI



Figure 1. Front view for model: EA2KSI, EA2.5KSI, EA3KSI



Figure 2. Rear view for model: EA2KSI, EA2.5KSI, EA3KSI

Product:

Grid-tied PV Inverter

Type:

EA2KSI, EA2.5KSI, EA3KSI, EA3KSI-D, EA3.68KSI,  
EA4KSI, EA4.6KSI, EA5KSI, EA6KSI



Figure 3. Terminal panel view for model: EA2KSI, EA2.5KSI, EA3KSI



Figure 4. Internal view-1 for model: EA2KSI, EA2.5KSI, EA3KSI

Product: Grid-tied PV Inverter  
Type: EA2KSI, EA2.5KSI, EA3KSI, EA3KSI-D, EA3.68KSI,  
EA4KSI, EA4.6KSI, EA5KSI, EA6KSI




Figure 5. Component side view of Main board for model: EA2KSI, EA2.5KSI, EA3KSI




Figure 6. Solder side view of Main board for model: EA2KSI, EA2.5KSI, EA3KSI



Product:

Grid-tied PV Inverter

Type:

EA2KSI, EA2.5KSI, EA3KSI, EA3KSI-D, EA3.68KSI,  
EA4KSI, EA4.6KSI, EA5KSI, EA6KSI



Figure 7. Front view for model: EA3KSI-D, EA3.68KSI, EA4KSI,  
EA4.6KSI, EA5KSI, EA6KSI




Figure 8. Rear view for model: EA3KSI-D, EA3.68KSI, EA4KSI,  
EA4.6KSI, EA5KSI, EA6KSI

Product:

Grid-tied PV Inverter

Type:

EA2KSI, EA2.5KSI, EA3KSI, EA3KSI-D, EA3.68KSI,  
EA4KSI, EA4.6KSI, EA5KSI, EA6KSI



Figure 9. Terminal panel view for model: EA3KSI-D, EA3.68KSI, EA4KSI, EA4.6KSI, EA5KSI, EA6KSI



Figure 10. Internal view-1 for model: EA3KSI-D, EA3.68KSI, EA4KSI, EA4.6KSI, EA5KSI

Product: Grid-tied PV Inverter  
Type: EA2KSI, EA2.5KSI, EA3KSI, EA3KSI-D, EA3.68KSI,  
EA4KSI, EA4.6KSI, EA5KSI, EA6KSI



Figure 11. Component side view of Main board for model: EA3KSI-D, EA3.68KSI, EA4KSI, EA4.6KSI, EA5KSI, EA6KSI




Figure 12. Solder side view of Main board for model: EA3KSI-D, EA3.68KSI, EA4KSI, EA4.6KSI, EA5KSI, EA6KSI

Product: Grid-tied PV Inverter  
Type: EA2KSI, EA2.5KSI, EA3KSI, EA3KSI-D, EA3.68KSI,  
EA4KSI, EA4.6KSI, EA5KSI, EA6KSI




Figura 13. Component side view of Control board

Product: Grid-tied PV Inverter  
Type: EA2KSI, EA2.5KSI, EA3KSI, EA3KSI-D, EA3.68KSI,  
EA4KSI, EA4.6KSI, EA5KSI, EA6KSI



Figure 14. Solder side view of Control board



Figure 15. Internal view-2 for model: EA6KSI