



A P P R O V A L S ®

Certificate of Suitability

* Addendum *

Certificate No.: SAA192448

Date of Issue: 16 September 2019

Class Description: Non-Prescribed

Product Description: Grid-connected PV Inverter

General Modification:

Hardware version: 00C

Software version: HornetV008

Additional Models	Trade Name	Rating
EA6KTSI	EAST	Input: Max 1000Vdc, MPPT voltage range: 120-950Vdc, Max 11A/11A, Isc: 12A/12A Output: 230/400V~ 3/N/PE, 50Hz 6000VA, 6000W, 8.7A
EA8KTSI	EAST	Input: Max 1000Vdc, MPPT voltage range: 120-950Vdc, Max 11A/11A, Isc: 12A/12A Output: 230/400V~ 3/N/PE, 50Hz 8000VA, 8000W, 11.6A
EA10KTSI	EAST	Input: Max 1000Vdc, MPPT voltage range: 200-950Vdc, Max 11A/11A, Isc: 12A/12A Output: 230/400V~ 3/N/PE, 50Hz 10000VA, 10000W, 14.5A
EA13KTSI	EAST	Input: Max 1000Vdc, MPPT voltage range: 200-950Vdc, Max 22A/11A, Isc: 24A/12A Output: 230/400V~ 3/N/PE, 50Hz 13000VA, 13000W, 18.9A
EA16KTSI	EAST	Input: Max 1000Vdc, MPPT voltage range: 200-950Vdc, Max 22A/11A, Isc: 24A/12A Output: 230/400V~ 3/N/PE, 50Hz 16000VA, 16000W, 23.2A

For and on Behalf of
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

www.saaapprovals.com.au

JAS-ANZ



Issued: 16-09-19 192448/2