



A P P R O V A L S ®

## Certificate of Suitability

**Certificate No.:** SAA192448

**Certificate Holder:** EAST Group Co., Ltd.  
No.6 Northern Industry Road,  
Songshan Lake Sci. & Tech. Industrial Park,  
Dongguan City,  
Guangdong Province,  
P.R. China

**Class Description:** Non-Prescribed  
**Product Description:** Grid-connected PV Inverter  
**Trade Name:** EAST  
**Model No.:** EA5KTSI  
**Markings:** Input: Max 1000Vdc, MPPT voltage range: 120-950Vdc,  
Max 11A/11A, Isc: 12A/12A  
Output: 230/400V~ 3/N/PE, 50Hz 5000VA, 5000W, 7.3A  
ta: -25°C to +60°C, IP65, Class I  
**Standard:** IEC 62109-1 Ed. 1.0  
IEC 62109-2 Ed. 1.0  
AS/NZS 4777.2:2015  
**Conditions:** Nil  
**Certification Mark:** SAA192448 or RCM  
**Date First Registered:** 16 September 2019  
**Date of Expiry:** 16 September 2024

For and on Behalf of  
SAA Approvals Pty Ltd


SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 and declared a RECS under *Qld Electrical Safety Act 2002 and Electrical Safety Regulations 2013* certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:

[www.saaapprovals.com.au](http://www.saaapprovals.com.au)

JAS-ANZ



Issued: 16-09-19 192448/1

[www.jas-anz.org/register](http://www.jas-anz.org/register)