

ATTESTATION OF CONFORMITY



Issued to : EAST Group Co., Ltd.
No.6 Northern Industry Road, Songshan Lake Sci. & Tech. Industrial Park,
Dongguan City, Guangdong Province, China

For the product : Grid-Connected PV Inverter

Trademark : EAST

Type/Model : EA5KTSI, EA6KTSI, EA8KTSI, EA10KTSI, EA13KTSI, EA16KTSI

Ratings : EA5KTSI, EA6KTSI, EA8KTSI:
Input: max 1000Vdc, MPPT voltage range: 120-950Vdc
Output: 230/400Vac, 50Hz, 5000VA / 6000VA / 8000VA
EA10KTSI, EA13KTSI, EA16KTSI:
Input: max 1000Vdc, MPPT voltage range: 200-950Vdc
Output: 230/400Vac, 50Hz, 10000VA / 13000VA / 16000VA

Manufactured by : EAST Group Co., Ltd.
No.6 Northern Industry Road, Songshan Lake Sci. & Tech. Industrial Park,
Dongguan City, Guangdong Province, China

Requirements : EN 61000-6-4:2007+A1:2011;
EN 61000-6-2:2005;
EN 61000-6-3:2007+A1:2011+AC:2012;
EN 61000-6-1:2007

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in test report No. 1942106E-IT-CE-P05V01.

This Attestation implies that the examined types are in accordance with the standards designated under the Electromagnetic compatibility directive 2014/30/EU.

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Shanghai, 19 June 2019

Number: 3181243.55AOC

DEKRA Testing and Certification (Shanghai) Ltd.

C. Lin
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed.

The CE marking may be affixed on the product if all relevant and effective EC directives are complied with



DEKRA Testing and Certification (Shanghai) Ltd.
3F 250 Jiangchangsan Road Shibe Hi-Tech Park, 200436 Jing'an District, Shanghai, China
T +86 21 6056 7666 F +86 21 6056 7555 www.dekra-certification.com