

ATTESTATION OF CONFORMITY

Issued to: EAST Group Co., Ltd.
No.6 Northern Industry Road, Songshan Lake Sci. & Tech. Industrial Park,
Dongguan City, Guangdong Province, China

For the product: Grid-connected PV Inverter

Trade name: **EAST**

Type/Model: EA20KTSI, EA25KTSI, EA30KTSI

Ratings: See Annex

Manufactured by: EAST Group Co., Ltd.
No.6 Northern Industry Road, Songshan Lake Sci. & Tech. Industrial Park,
Dongguan City, Guangdong Province, China

Requirements: EN 50549-1:2019

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no 6070851.50.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

Arnhem, 10 January 2020

Number: 6070851.01AOC

DEKRA Testing and Certification (Shanghai) Ltd.


Kreny Lin
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

Page 1 of 2

DEKRA Testing and Certification (Shanghai) Ltd.

3F #250 Jiangchangsan Road Building 16 Headquarter Economy Park Shibe Hi-Tech Park, Jing'an District, Shanghai 200436 China
T +86 21 6056 7600 F +86 21 6056 7555 www.dekra-certification.com

Annex to 6070851.01AOC

Ratings of the test product:

EA20KTSI:

PV input: Max. 1100 Vdc , MPPT voltage range: 200-950 Vdc , max 22 A/22 A, Isc PV: 24 A/24 A

Output: 230/400 Vac, 3/N/PE, 50/60 Hz, 20000 VA, max 29.0 A

EA25KTSI:

PV input: Max. 1100 Vdc , MPPT voltage range: 200-950 Vdc , max 33 A/22 A, Isc PV: 36 A/24 A

Output: 230/400 Vac, 3/N/PE, 50/60 Hz, 25000 VA, max 36.3 A

EA30KTSI:

PV input: Max. 1100 Vdc , MPPT voltage range: 200-950 Vdc , max 33 A/33 A, Isc PV: 36 A/36 A

Output: 230/400 Vac, 3/N/PE, 50/60 Hz, 30000 VA, max 43.5 A