

ATTESTATION OF CONFORMITY

Issued to: EAST Group Co., Ltd.
No. 6 Northern Industry Road, Songshan Lake Sci. & Tech. Industrial Park,
Dongguan City, Guangdong Province, China

For the product: Grid-Connected PV Inverter

Trade name: EAST

Type/Model: EA20KTSI; EA25KTSI; EA30KTSI

Ratings: Input: max 1100 Vdc, MPPT voltage range: 200-950 Vdc,
Output: 230/400 Vac, 3/N/PE, 50/60 Hz, 20000 W / 25000 W / 30000 W

Manufactured by: EAST Group Co., Ltd.
No. 6 Northern Industry Road, Songshan Lake Sci. & Tech. Industrial Park,
Dongguan City, Guangdong Province, China

Requirements: EN 61000-6-4:2007+A1:2011
EN 61000-6-2:2005
EN 61000-6-1:2007
EN 61000-6-3:2007+ A1:2011+AC:2012

This Attestation is granted on account of an examination by DEKRA; the results of which are laid down in a confidential file no 1992142E-ISM-CE-P05V01.

This Attestation implies that the examined types are in accordance with the standard.

The examination has been carried out on one single specimen or several specimens of the product; submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

The CE marking may be affixed on the product if all relevant and effective EC directives are complied with.

Arnhem, 05 November 2019

Number: 3181243.67AOC

DEKRA Testing and Certification (Shanghai) Ltd.

Cliff Lin
Certification Manager



© Integral publication of this attestation and adjoining reports is allowed

